



Peter Matchak <pmatchak@ashlandmass.com>

Revised Site Plan 9-490 Homer Ave

Lyn Moraghan <lmoraghan@ashlandfire.com>
To: Peter Matchak <pmatchak@ashlandmass.com>

Fri, Apr 7, 2023 at 11:59 AM

Hi Peter,

The Chief and I have looked at the revised plan and would request a **Swift Path Analysis** of a 40' Box truck to be completed by their engineering team. This swift path analysis is a standard request we make on any new commercial property. We usually require it to be done with our Tower specs but in this occasion, we would only require the equivalent of our Engine. We also would like the area across from the entrance named "drop off area" to be marked and utilized for both drop off and emergency vehicles only. This area we would utilize for emergency vehicles that respond with the ambulance, so we would need to have it open. By placing the apparatus there it will allow other parked traffic to leave without any issue.

Thanks and have a great weekend,

Lyn

[Quoted text hidden]

[Quoted text hidden]

Please remember when writing or responding, the Massachusetts Secretary of State has determined that e-mail is a public record. This e-mail is intended to be conveyed only to the designated recipient(s) named above. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is not authorized and may be unlawful.



Lyn Moraghan
Deputy Chief
Ashland Fire Department
a. 70 Cedar Street Ashland MA, 01721
p: (508) 532 7993



Please remember when writing or responding, the Massachusetts Secretary of State has determined that e-mail is a public record. This e-mail is intended to be conveyed only to the designated recipient(s) named above. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is not authorized and may be unlawful.