



Peter Matchak <pmatchak@ashlandmass.com>

9-49 Homer Street Plan Review

Keith Roble <krobie@ashlandfire.com>
To: Peter Matchak <pmatchak@ashlandmass.com>

Fri, Nov 3, 2023 at 2:38 PM

Peter,

Looks like the swept path analysis shows we can make it, it does look tight in the back but as long as it is passable for the trucks.

The loading area I think is fine to be shareable. Ultimately I would prefer no long term parking there so it is open most of the time if needed. I just see us blocking up everything during a call so good to have some area to pull off.

As far as sprinkler I can be open to either area, but would like to see the fire sprinkler connection in the area it is marked currently as (building corner near Homer and Alden). There is a hydrant right across st for that. If it was relocated, I would prefer a hydrant to be added to property in the same area.

Thanks
Chief Robie

[Quoted text hidden]

[Quoted text hidden]

Please remember when writing or responding, the Massachusetts Secretary of State has determined that e-mail is a public record. This e-mail is intended to be conveyed only to the designated recipient(s) named above. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is not authorized and may be unlawful.

—
Chief Keith Robie
Ashland Fire Department
12 Union Street
Ashland, MA 01721
508-532-7991

Please remember when writing or responding, the Massachusetts Secretary of State has determined that e-mail is a public record. This e-mail is intended to be conveyed only to the designated recipient(s) named above. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is not authorized and may be unlawful.

