

May 15, 2018

RE: 368 Chestnut St. application

All,

In reference to the addition submitted to the application, the numbered responses refer to an email I had wrote to the applicant following review from the Building Commissioner and the Fire Chief, as well as Stu's request for additional information. The applicant's responses are numbered according to the following comments/questions:

1. The stove needs a vent and a hood.
2. The egress window above the sink won't work. Another egress must be proposed.
3. The bathroom needs a fan that exits to the outside.
4. The bedroom needs to be walled off, with a door, and the egress window must be in the bedroom.
5. a)The egress window needs additional information, such as dimensions.
b) Additional information on the egress is needed. Does it come out to grade, or are there steps?
6. Where will people park?
7. a)The living room, bedroom, play room, and furnace room all need smoke and CO detectors.
b) A heat sensor is needed above the dryer.
- 8-13. These are the responses to the criteria stated in Chapter 9.3.2.

Let me know if you have any questions.

Thanks.

Josh