



Peter Matchak <pmatchak@ashlandmass.com>

100 Fountain Street Conservation Review

Becca Solomon <bsolomon@ashlandmass.com>

Thu, Mar 24, 2022 at 2:49 PM

To: Peter Matchak <pmatchak@ashlandmass.com>

Cc: Emma Snellings <esnellings@ashlandmass.com>, Tricia Kendall <tkendall@ashlandmass.com>

Hi Peter,

The plan as shown will require a Stormwater Management Permit under the local Stormwater Bylaw, prior to the beginning of construction. The roads themselves will likely not require anything more than an SMP from Conservation; however part of the property does have Wetland Buffer Zone on it, which may require filing if it is developed in future plans. The buffer zone is located off of Highland Road, in the corner of Parcel A.

Thank you,
-Becca



Becca Solomon
Conservation Agent
Town of Ashland
a: 101 Main Street, Ashland MA 01721
p: 508-532-7924
f: 508-881-0162



Please remember when writing or responding, the Massachusetts Secretary of State has determined that e-mail is a public record. This e-mail is intended to be conveyed only to the designated recipient(s) named above. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is not authorized and may be unlawful.

[Quoted text hidden]